

JAIPUR VIDYUT VITRAN NIGAM LIMITED
Office of the Superintending Engineer (RM&DF)

No. JVVNL/SE(RM&DF)/XEN(RM)/F./D.

178

Dated:

3-11-2017

ADCT-17
Dkt. Com 6/11

The Secretary,
Raj. Electricity Regulatory Commission,
Jaipur.

↓
STU

Sub:- Time bound activities mandated for the Discoms, for
improvement in the Standards of Performances as per
SOP Regulations, 2014 for the period **April 17 to Sept 17**

Sir,

Please find enclosed herewith the information of half yearly time bound activities of Standards of Performances as per SOP Regulations, 2014, in prescribed formats SOP-1 to SOP-5 for the period **April 17 to Sept 17** in respect of Jaipur Discom for kind perusal and further needful of the commission.

It is also submitted that for implementation of BRAP (Business resource action plan) of GOR, quarterly information of frequency and total duration of outages in format SOP-4 and SOP-5 from (April 17 to June 17 & July 17 to Sept 17)) is also being enclosed to be published on Commission's website.

Encl.:- As above.

Yours faithfully,

Attan

(S.T.Hussain)

Executive Engineer(RM)

Copy forwarded to the Registrar, office of the Electricity Ombudsman of Rajasthan, Jaipur along with the information in prescribed format.

Encl: - SOP-1 to SOP-5

Attan

Executive Engineer(RM)

PR No
1622
3/11/17

Distribution SOP Reporting Formate
Reliability Indices

System Average Interruption Frequency Index (SAIFI)

SOP-4

For the quarter April 17 to June 17

Name of Licensee : Jaipur Discom

S.NO.	Name of Circle	Total no of consumer served (1)	Total numbers of sustained interruptions to consumers (2)	SAIFI=(2)/(1) (No. of interruptions/Consumers)	Target specified by the commission
1	JCC	805432	27169	0.0337	
2	JPDC	685912	14206	0.0207	
3	DAUSA	286933	8736	0.0304	
4	ALWAR	639540	10108	0.0158	
5	TONK	219366	5459	0.0249	
6	BHARATPUR	277192	119155	0.4299	
7	SAWAI MADHOPUR	195329	3031	0.0155	
8	DHOLPUR	107568		0.0000	
9	KARAULI	168368	19861	0.1180	
10	KOTA	337521	16064	0.0476	
11	BARAN	205131	2660	0.0130	
12	BUNDI	170542	4442	0.0260	
13	JHALAWAR	217586	1189	0.0055	
	TOTAL	4316420	232079	0.0538	

Distribution SOP Reporting Formate
Reliability Indices
System Average Interruption Duration Index (SAIDI)

SOP-5

For the quarter April 17 to June 17

Name of Licensee : Jaipur Discom

S.NO.	Name of Circle	Toatal no of consumer served (1)	Total minutes of sustained interruptions to consumers (2)	SAIDI=(2)/(1) (Minutes/Consumers)	Target specified by the commission
1	JCC	805432	102087	0.127	
2	JPDC	685912	217779	0.318	
3	DAUSA	286933	146128	0.509	
4	ALWAR	639540	16002	0.025	
5	TONK	219366	48840	0.223	
6	BHARATPUR	277192	596366	2.151	
7	SAWAI MADHOPUR	195329	32049	0.164	
8	DHOLPUR	107568	0	0.000	
9	KARALI	168368	2466	0.015	
10	KOTA	337521	32128	0.095	
11	BARAN	205131	6435	0.031	
12	BUNDI	170542	10440	0.061	
13	JHALAWAR	217586	5077	0.023	
	TOTAL	4316420	1215796	0.282	