

JAIPUR VIDYUT VITRAN NIGAM LIMITED
Office of the Superintending Engineer (RM&DF)

No. JVVNL/SE(RM&DF)/XEN(RM)/F./D.

178
3-11-2017

Dated:

ADCT-1) (RM)
Discom 6/11
↓
STU

The Secretary,
Raj. Electricity Regulatory Commission,
Jaipur.

Sub:- Time bound activities mandated for the Discoms, for
improvement in the Standards of Performances as per
SOP Regulations, 2014 for the period **April 17 to Sept 17**

Sir,

Please find enclosed herewith the information of half yearly time bound activities of Standards of Performances as per SOP Regulations, 2014, in prescribed formats SOP-1 to SOP-5 for the period **April 17 to Sept 17** in respect of Jaipur Discom for kind perusal and further needful of the commission.

It is also submitted that for implementation of BRAP (Business resource action plan) of GOR, quarterly information of frequency and total duration of outages in format SOP-4 and SOP-5 from (April 17 to June 17 & July 17 to Sept 17)) is also being enclosed to be published on Commission's website.

Encl.:- As above.

Yours faithfully,

Attan

(S.T.Hussain)

Executive Engineer(RM)

Copy forwarded to the Registrar, office of the Electricity Ombudsman of Rajasthan, Jaipur along with the information in prescribed format.

Encl: - SOP-1 to SOP-5

Attan

Executive Engineer(RM)

PR no
1622
3/11/17

Distribution SOP Reporting Formate
Reliability Indices

System Average Interruption Frequency Index (SAIFI)

SOP-4

For the quarter July 17 to Sept 17

Name of Licensee : Jaipur Discom

S.NO.	Name of Circle	Total no of consumer served (1)	Total numbers of sustained interruptions to consumers (2)	SAIFI=(2)/(1) (No. of interruptions/Consumers)	Target specified by the commission
1	JCC	805432	33206	0.0412	
2	JPDC	685912	17363	0.0253	
3	DAUSA	286933	10677	0.0372	
4	ALWAR	639540	12354	0.0193	
5	TONK	219366	6672	0.0304	
6	BHARATPUR	277192	145633	0.5254	
7	SAWAI MADHOPUR	195329	3704	0.0190	
8	DHOLPUR	107568		0.0000	
9	KARALI	168368	24275	0.1442	
10	KOTA	337521	19634	0.0582	
11	BARAN	205131	3252	0.0159	
12	BUNDI	170542	5429	0.0318	
13	JHALAWAR	217586	1454	0.0067	
	TOTAL	4316420	283653	0.0657	

Distribution SOP Reporting Formate
Reliability Indices

System Average Interruption Duration Index (SAIDI)

SOP-5

For the quarter July 17 to Sept 17

Name of Licensee : Jaipur Discom

S.NO.	Name of Circle	Toatal no of consumer served (1)	Total minutes of sustained interruptions to consumers (2)	SAIDI=(2)/(1) (Minutes/Consumers)	Target specified by the commission
1	JCC	805432	124773	0.155	
2	JPDC	685912	266175	0.388	
3	DAUSA	286933	178600	0.622	
4	ALWAR	639540	19558	0.031	
5	TONK	219366	59693	0.272	
6	BHARATPUR	277192	728892	2.630	
7	SAWAI MADHOPUR	195329	39170	0.201	
8	DHOLPUR	107568	0	0.000	
9	KARAUJI	168368	3013	0.018	
10	KOTA	337521	39268	0.116	
11	BARAN	205131	7865	0.038	
12	BUNDI	170542	12759	0.075	
13	JHALAWAR	217586	6206	0.029	
	TOTAL	4316420	1485973	0.344	